

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 11:37 am

**PWS ID:** UTAH02051      **Name:** CEDAR RIDGE DISTRIBUTION COMPANY  
**Legal Contact:** CEDAR RIDGE DISTRIBUTION COMPAN      **Rating:** Approved  
DAVID Z THOMPSON      **Rating Date:** 05/14/2008  
**Address:** 12435 N HILLCREST      **Activity Status:** Active  
DEWEYVILLE, UT 84309  
**Phone Number:** 435-257-7152  
**City Served (Area):**  
**County:** BOX ELDER COUNTY  
**System Type:** Community      **Last Inv Update:** 06/22/2011      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 05/24/2010      **Total Dsgn Cap:**  
**Population:** 100      **Surveyor:** DAVID F HANSEN      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day    Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	THOMPSON, DAVID Z	MANAGER	435-257-7152	435-230-0876	zcabinets@comcast.net

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unknown	0	32
			32    Total Svc Connections

### Storage

**Total Storage:** 150,000 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	75,000 GAL	Concrete		A	
ST002	STORAGE FACILITY ST002	Ground	75,000 GAL	Concrete		A	

### Distribution System

Pump Type	Total Dyn Head ft H2O    P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	1976 WELL	Active	WL	8	25 GPM	25 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	1986 WELL (SOLD)	Inactive	WL	16	1200 GPM	1,200 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	UTAH02011 TREMONTON C	Active	CC				No	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.